

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Nowata Municipal Authority

We routinely monitor for the presence of drinking water contaminants. Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Nowata Municipal Authority Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

Testing results we received for July 2018 through June 2019 show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes. The standard or MCL for total trihalomethanes is 0.080 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's locations was **0.084 mg/L**.

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

CORRECTIVE ACTION

The Water Treatment Plant operators have mad adjustment to the Water Treatment Plant and are continuing to sample and monitor the turbidity levels in the drinking water to ensure that the municipal water is safe and pleasent for all its customers.

For further information contact:

City Hall
114 South Maple Street
Nowata, OK 74048
918-273-3838

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Nowata Municipal Authority

PWSID#: OK 1021503

NOV #: P-1021503-19-2

Date Distributed:

8-5-2019